



产品认证证书

证书编号：CQC2016010305903944

申请人名称及地址

欣灵电气股份有限公司
浙江省乐清经济开发区纬十九路 328 号

制造商名称及地址

欣灵电气股份有限公司
浙江省乐清经济开发区纬十九路 328 号

生产企业名称及地址

欣灵电气股份有限公司(V041165)
浙江省乐清经济开发区纬十九路 328 号

产品名称和系列、规格、型号

电感式接近开关

CHJ; Ui:250V;Ue:AC100V~AC240V;DC10V~DC30V;Ie:200mA;Sn:1.5mm、2mm、4mm、5mm、10mm、15mm;f:25Hz;AC-12,DC-12;IP65;型号解释详见附件

产品标准和技术要求

GB/T 14048.10-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求，特发此证。

发证日期：2020 年 03 月 12 日 有效期至：2021 年 09 月 19 日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任：_____

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0199373



产品认证证书

附录:

第 1 页 共 1 页

证书编号: CQC2016010305903944

纸号: 199373

型号的解释:

CH	J	□	M	-	□	□	□
(1)	(2)	(3)	(4)		(5)	(6)	(7)

(1) 企业代号

(2) 电感式

(3) 外形尺寸: 规格有: 8、12、17、18、30 分别表示 8mm、12mm、17mm、18mm、30mm

(4) 安装方式: M 非埋入式, 无代号埋入式

(5) 检测距离: 1.5mm、2mm、4mm、5mm、10mm、15mm

(6) 型号 N: NPN 型; P: PNP 型; 型号 D: 直流 2 线型; 型号 A: 交流 2 线型

(7) 输出状态 1: NO 2: NC 4: NO+NC

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2016010305903944

NAME AND ADDRESS OF THE APPLICANT

Xinling Electrical Co.,Ltd.
No.328, Wei 19th Road, Yueqing Economic Development Area, Zhejiang Province, P.R China

NAME AND ADDRESS OF THE MANUFACTURER

Xinling Electrical Co.,Ltd.
No.328, Wei 19th Road, Yueqing Economic Development Area, Zhejiang Province, P.R China

NAME AND ADDRESS OF THE FACTORY

Xinling Electrical Co.,Ltd. (V041165)
No.328, Wei 19th Road, Yueqing Economic Development Area, Zhejiang Province, P.R China

PRODUCT NAME, MODEL AND SPECIFICATION

Inductive Proximity Switches
CHJ; Ui:250V;Ue:AC100V~AC240V;DC10V~DC30V;Ie:200mA;Sn:1.5mm、2mm、4mm、5mm、10mm、
15mm;f:25Hz;AC-12,DC-12;IP65;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.10-2016

TYPE OF CERTIFICATION SCHEMES

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Mar.12,2020

Valid until: Sep.19,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0199373